

PERKINS TOWNSHIP

Building & Zoning Division
2610 Columbus Avenue
Sandusky, Ohio 44870

PLANNING & DEVELOPMENT DEPARTMENT

Ph: 419-609-1435

www.perkinstownship.com

Plan Submittal Checklist**Pre-Engineered Fire Suppression System Installation & Replacement**

The following information shall be provided on all documents submitted for Plan Approval for Fire Alarm Systems:

- 1. Does the scope of work involve the installation of a new Exhaust system, or the modification to an existing exhaust system?
_____ No (if no, please make note on plans to this effect)
_____ Yes (if yes, plans and specifications of this work must be provided from a registered design professional, along with the applicable review fees)

- 2. Is the scope of this work limited to the replacement only of the U.L. 300 pre-engineered suppression system piping only?
_____ Yes
_____ No (if no, any work involving fire alarm interconnections, structural or electrical work must be submitted by a registered design professional along with the applicable review fees)

- 3. Provide exhaust hood and duct details from hood to exhaust fan termination.
- 4. Indicate pipe sizes and materials, nozzle types and flow point calculations.
- 5. Indicate Certified Installer Certification numbers.
- 6. Indicate manual pull station locations.
- 7. Indicate power/fuel shut-off to appliances.
- 8. Indicate discharge warning signage.
- 9. Provide a copy of the system design manual along with cylinder capacities and locations.
- 10. Provide a kitchen plan and appliance information.